



# **POWERED BY:**



TOTAL COOLANT CAPACITY (LITERS)

GENSET IMAGE IS FOR ILLUSTRATION PURPOSE ONLY

GENERATOR SET MODEL (GPD 8 0)		
OUTPUT RATINGS (1500 RPM @ 0.8 P.F)	PRIME	STANDBY
400 V, 50 Hz @ 50 °C ∧mBIENT	80 KVV	85 KV/\

		1	
ENGINE / TECHNIC	CAL DATA		
Make (ORIGIN)		Do	OOSAN (KOREA)
Model			D11-46
GOVERNING TYPE			MECHANICAL
NUMBER OF CYLINDERS	5		06
CYLINDER ARRANGEME	NT		IN-LINE
BORE AND STROKE MA	ባ		111 & 139
DISPLACEMENT ( LITERS	5)		8.07
CYCLE			04
COMBUSTION SYSTEM			DIRECT
COMPRESSION RATIO			17.5:1
ROTATION		Coun	JTER CLOCK WISE
		VIEWE	FROM FLYWHEEL
COOLING SYSTEM		V	Inter Cooled
FREQUENCY AND ENGIN	NE SPEED	50 H	1Z & 1500 RPM
			PRIME
GROSS ENGINE POWER KW		77	
FUEL CONSUMPTION	@ 100% LOA		15.36
	@ <b>75</b> % LOAD		11.52
	@ <b>50%</b> LOAD		7.68
LUBRICATION SYSTEM CAPACITY (LITERS		)	15.5

DIMENSIONS ANI	D WEIGHT		
LENGTH (MM)	Wіртн (мм)	HEIGHT (MM)	WEIGHT (KG)
1216	736	976	1100

# *GPD 80*

# 1. ENGINE

DOOSAN O4 STROKE HEAVY DUTY WITH HIGH PERFORMANCE INDUSTRIAL TYPE DIESEL ENGINE.

#### 2. COOLING SYSTEM

THE ENGINE COOLING SYSTEM IS A FRESH WATER FORCED CIRCULATION TYPE & CONSISTS OF:

- $\Lambda$  RADIATOR WITH MECHANICAL FAN SUITABLE FOR OPERATION IN  $\Lambda$  TEMPERATURE OF 50  $^{\circ}$ C.
- ↑ THERMOSTAT FOR AUTOMATIC CONTROL OF WATER COOLANT TEMPERATURE.
- A COOLING WATER PUMP.

## 3. LUBRICATION OIL SYSTEM

- LUBRICATING OIL GEAR PUMP & SUMP WITH DRAIN VALVE FOR PRESSURE LUBRICATION.
- SPIN ON FULL FILTER & CARTRIDGE OIL FILTER.
- . OIL COOLER.
- MANUAL PUMP FOR EMPTYING THE SUMP.
- LUBE OIL HEATERS.
- GEARED FUEL PUMP.
- SPIN & CARTRIDGE FUEL FILTER.
- FUEL INJECTION PUMP WITH MECHANICAL SPEED REGULATOR.

# 4. COMBUSTION AIR SUPPLY SYSTEM DRY AIR FILTER WITH CLOGGING INDICATOR.

#### 5. EXHAUST SYSTEM

WATER COOLED FLANGED EXHAUST MANIFOLD SYSTEM WITH INDUSTRIAL TYPE EXHAUST SILENCER FOR REMOTE MOUNTING. EXPANSION GASKET FITTED ON OUTLET WITH S.S INSULATED PIPES TO AVOID ANY CONTACT WITH HOT AREAS.

# **6. STARTING SYSTEM**

ELECTRIC STARTER WITH BATTERY CHARGER ALTERNATOR COMPLETE WITH AUTOMATIC VOLTAGE REGULATOR, 24 V LEAD ACID STARTER BATTERIES.

# 7. ELECTRICAL EQUIPMENT FOR AUTOMATIC OPERATION

- MINIMUM OIL PRESSURE CONTACT.
- Excessive water temperature contact.
- COOLANT WATER PREHEAT WITH THERMOSTATIC CONTROL.

# 8. COUPLING

THE GENERATOR SET (ENGINE & ALTERNATOR) IS DIRECTLY COUPLED ON A WELDED STEEL MS GIRDER PLATFORM BY MEANS OF AN SAE FLANGE. THERE ARE A SERIES OF RUBBER ABSORPTION DAMPERS INSTALLED BETWEEN THE GENERATOR SET AND THE FRAME TO ABSORB ANY VIBRATIONS THE GENERATOR SET MIGHT PRODUCE.

## 9. FUEL SYSTEM

14

THE BASE FRAME WILL HAVE A BUILT-IN FUEL TANK WITH A MINIMUM CAPACITY OF 300 LITERS OR 10 HOURS ON FULL LOAD.

(CONT.)

ALTERNATOR / TECHNICAL DATA			
MAKE (ORIGIN	ν)	MARELLI (MALAYSIA)	
MODEL		MJB-225-SB4	
POWER FACTO	OR	0.8	
FREQUENCY (Hz)		50	
INGRESS Pro	TECTION	IP 23	
INSULATION C	inss	Н	
RATED SPEED	(RPM)	1500	
VOLTAGE REG	ULATION (STEADY)	Nuto (with accuracy of $\pm$ 0.5 %)	
Exciting Mo	DE	Brushless (Self Excitation)	
PHASE AND T	HREADS	O3 PHASE AND O4 WIRES	
OVERLOAD		10% for 1 hour every 12 hours	
WINDING PITE	CH (# OF LEADS)	2/3	
COUPLING		FLEXIBLE DISC	
SENSORS		WINDING TEMPERATURE SENSORS	
TOTAL HARMO	DNIC CONTENT	< 2% - AT NO LOAD	
AVR Model	(CODE)	Mark V (M16FA655A)	
STANDARDS	IEC 60034-1; CEI 2-3; BS 4999-5000; NEMA MG 1.22		

# **RATINGS DEFINITION**

#### PRIME POWER:

POWER AVAILABLE AT VARIABLE LOAD IN LIEU OF MAIN POWER NETWORK. AN OVERLOAD OF 10% IS PERMITTED FOR ONE HOUR IN EVERY TWELVE HOURS OF OPERATION.

#### STANDBY POWER:

POWER AVAILABLE AT VARIABLE LOAD IN THE EVENT OF A MAIN POWER NETWORK FAILURE.NO OVERLOAD IS PERMITTED.

THESE RATINGS ARE APPLICABLE FOR SUPPLY CONTINUOUS ELECTRICAL POWER (AT VARIABLE LOAD) IN THE EVENT OF A UTILITY POWER FAILURE. NO OVERLOAD IS PERMITTED ON THESE RATINGS

## STANDARD REFERENCE CONDITIONS

OUTPUT RATINGS ARE PRESENTED AT 30°C AIR INLET TEMPERATURE, BAROMETRIC PRESSURE 100 KPA, RELATIVE HUMIDITY 30%. THIS GENERATING SET IS DESIGNED TO OPERATE AT HIGH AMBIENT TEMPERATURES (UP TO 55°C), HUMIDITY (UP TO 99%) AND HIGHER ALTITUDES. DE-RATION MAY APPLY, PLEASE CONSULT YOUR DEALER FOR SPECIFIC SITE RATINGS AND SMOOTH OPERATION.

# AVAILABLE OPTIONS & ACCESSORIES

WE OFFER A RANGE OF OPTIONAL FEATURES AND ACCESSORIES TO TAILOR OUR GENERATING SETS TO MEET YOUR POWER NEEDS.

######################################		
SOUND / WEATHER PROOF CANOPY	ATS / AMF PANELS	
SYNCHRONIZING PANELS	WATER FUEL SEPARATOR	
ADDITIONAL PROTECTION ALARMS AND SHUTDOWNS		
WATER JACKET HEATER	CABLING AND DUCTING	
REMOTE MONITORING SYSTEM	EARTHING SYSTEM	

THE RECOGNIZE BRAND OF



10. GENERATOR CONTROL PANEL		
Make	DEEP SEA	
Model	DSE-4520	

THE MAIN CONTROL PANEL CABINET PROVIDES AN AUTOMATIC CONTROL FOR THE STARTING OF THE GENERATOR SET WHEN A MAINS FAILURE OCCURS. THE DSE-4520 IS AN AUTO START CONTROL MODULE FOR SINGLE GENSET APPLICATIONS. IT INCLUDES A BACKLIT LCD DISPLAY WHICH CLEARLY SHOWS THE STATUS OF THE ENGINE ALL THE TIMES, THIS MODULE CAN EITHER BE PROGRAMMED USING THE FRONT PANEL OR BY USING THE DSE CONFIGURATION SUITE PC SOFTWARE. THE CABINET INCLUDES.

- CIRCUIT BREAKER(S)
- Bus Bar
- Measuring Instruments
  - VOLTMETER
  - **AMPERE METER**
  - FREQUENCY METER
  - TIME (HOURS) REORDER
  - KILOWATT METER
- ALARMS
  - FAILURE TO START
  - Low Lubricating oil Pressure
  - UNDER/OVER VOLTAGE
  - OVER FREQUENCY
  - High coolant temperature switch
  - OVER CRANK
  - GENERATOR OVER LOAD
- GAUGES
  - OIL PRESSURE GAUGE
  - WATER TEMPERATURE GAUGE
  - RPM METER
  - CHARGING AMMETER
  - EMERGENCY STOP PUSH BUTTON
- SELECTORS
  - To select the generator's operating mode "OFF-AUTOMATIC -MANUAL AND TEST"
  - To switch the generator to test position: "on-off"
- Pushbuttons
  - EMERGENCY SHUTDOWN RED BUTTON
- SAFETIES
  - FAILURE TO START
  - Low Lubricating oil Pressure
  - UNDER/OVER VOLTAGE
  - OVER FREQUENCY
  - High coolant temperature switch
  - OVER CRANK
  - GENERATOR OVER LOAD
  - FAIL TO START / OVER CRANK

#### 11. FACTORY TESTS

THE GENERATING SET IS LOAD TESTED BEFORE DISPATCH IN OUR FACTORY. ALL PROTECTIVE DEVICES ARE SIMULATED. THE GENERATOR AND ITS SYSTEM ARE CHECKED BEFORE DISPATCH.

## 12. DOCUMENTATION

ONE SET OF COMPLETE SPARE PARTS LIST, ENGINE & ALTERNATOR MAINTENANCE MANUAL.

ONE SET OF ENGINE OPERATION MANUAL AND PART CATALOGUE.