



GENSET IMAGE IS FOR ILLUSTRATION PURPOSE ONLY

GENERATOR SET MODEL (GPD 200)		
OUTPUT RATINGS (1500 RPM @ 0.8 P.F)	PRIME	STANDBY
400 V, 50 Hz @ 50 °C ΛΜΒΙΕΝΤ	200 KVV	225 KV/\

ENGINE / TECHNICAL DATA				
Make (origin)		Doosan (Korea)		
Model		P-086-TI		
GOVERNING TYPE			MECHANICAL	
NUMBER OF CYLINDER	S		06	
CYLINDER ARRANGEME	NT		IN-LINE	
BORE AND STROKE MA	Ŋ		111 & 139	
DISPLACEMENT ( LITERS	5)		8.07	
CYCLE			04	
COMBUSTION SYSTEM			DIRECT	
COMPRESSION RATIO			16.8:1	
ROTATION		Coun	JTER CLOCK WISE	
		VIEWE	FROM FLYWHEEL	
COOLING SYSTEM		V	Inter Cooled	
FREQUENCY AND ENGINE SPEED		50 HZ & 1500 RPM		
			PRIME	
GROSS ENGINE POWER KW		177		
FUEL CONSUMPTION	@ 100% LOAD L/HR @ 75% LOAD L/HR		38.4	
			28.8	
	@ 50% LOAD L/HR		19.2	
LUBRICATION SYSTEM CAPACITY (LITERS)		)	15.5	
TOTAL COOLANT CAPACITY (LITERS)			14	

DIMENSIONS AND WEIGHT				
LENGTH (MM)	Wіртн (мм)	HEIGHT (MM)	WEIGHT (KG)	
1242	923	1095	1620	

### GPD 200

#### 1. ENGINE

DOOSAN O4 STROKE HEAVY DUTY WITH HIGH PERFORMANCE INDUSTRIAL TYPE DIESEL ENGINE.

#### 2. COOLING SYSTEM

THE ENGINE COOLING SYSTEM IS A FRESH WATER FORCED CIRCULATION TYPE & CONSISTS OF:

- $\Lambda$  RADIATOR WITH MECHANICAL FAN SUITABLE FOR OPERATION IN  $\Lambda$  TEMPERATURE OF 50  $^{\circ}$ C.
- ↑ THERMOSTAT FOR AUTOMATIC CONTROL OF WATER COOLANT TEMPERATURE.
- A COOLING WATER PUMP.

#### 3. LUBRICATION OIL SYSTEM

- LUBRICATING OIL GEAR PUMP & SUMP WITH DRAIN VALVE FOR PRESSURE LUBRICATION.
- SPIN ON FULL FILTER & CARTRIDGE OIL FILTER.
- . OIL COOLER.
- MANUAL PUMP FOR EMPTYING THE SUMP.
- LUBE OIL HEATERS.
- GEARED FUEL PUMP.
- SPIN & CARTRIDGE FUEL FILTER.
- FUEL INJECTION PUMP WITH MECHANICAL SPEED REGULATOR.

## 4. COMBUSTION AIR SUPPLY SYSTEM DRY AIR FILTER WITH CLOGGING INDICATOR.

#### 5. EXHAUST SYSTEM

WATER COOLED FLANGED EXHAUST MANIFOLD SYSTEM WITH INDUSTRIAL TYPE EXHAUST SILENCER FOR REMOTE MOUNTING. EXPANSION GASKET FITTED ON OUTLET WITH S.S INSULATED PIPES TO AVOID ANY CONTACT WITH HOT AREAS.

#### 6. STARTING SYSTEM

ELECTRIC STARTER WITH BATTERY CHARGER ALTERNATOR COMPLETE WITH AUTOMATIC VOLTAGE REGULATOR, 24 V LEAD ACID STARTER BATTERIES.

## 7. ELECTRICAL EQUIPMENT FOR AUTOMATIC OPERATION

- MINIMUM OIL PRESSURE CONTACT.
- Excessive water temperature contact.
- COOLANT WATER PREHEAT WITH THERMOSTATIC CONTROL.

#### 8. COUPLING

THE GENERATOR SET (ENGINE & ALTERNATOR) IS DIRECTLY COUPLED ON A WELDED STEEL MS GIRDER PLATFORM BY MEANS OF AN SAE FLANGE. THERE ARE A SERIES OF RUBBER ABSORPTION DAMPERS INSTALLED BETWEEN THE GENERATOR SET AND THE FRAME TO ABSORB ANY VIBRATIONS THE GENERATOR SET MIGHT PRODUCE.

#### 9. FUEL SYSTEM

THE BASE FRAME WILL HAVE A BUILT-IN FUEL TANK WITH A MINIMUM CAPACITY OF 500 LITERS OR 10 HOURS ON FULL LOAD.

(CONT.)

ALTERNATOR / TECHNICAL DATA		
Make (ORIGIN)	MARELLI (MALAYSIA)	
Model	MJB-250-L/\d	
POWER FACTOR	0.8	
FREQUENCY (Hz)	50	
INGRESS PROTECTION	IP 23	
INSULATION CLASS	Н	
RATED SPEED (RPM)	1500	
VOLTAGE REGULATION (STEADY)	NUTO (WITH ACCURACY OF $\pm$ 0.5 %)	
EXCITING MODE	Brushless (Self Excitation)	
PHASE AND THREADS	O3 PHASE AND O4 WIRES	
OVERLOAD	10% FOR 1 HOUR EVERY 12 HOURS	
WINDING PITCH (# OF LEADS)	2/3 (12)	
COUPLING	FLEXIBLE DISC	
SENSORS	WINDING TEMPERATURE SENSORS	
TOTAL HARMONIC CONTENT	< 2% - AT NO LOAD	
AVR MODEL (CODE)	Млк V (М16FЛ655Л)	
STANDARDS IEC 60034-1; CEI 2-3; BS 4999-5000; NEMA MG 1.22		

#### **RATINGS DEFINITION**

#### PRIME POWER:

POWER AVAILABLE AT VARIABLE LOAD IN LIEU OF MAIN POWER NETWORK. AN OVERLOAD OF 10% IS PERMITTED FOR ONE HOUR IN EVERY TWELVE HOURS OF OPERATION.

#### STANDBY POWER:

POWER AVAILABLE AT VARIABLE LOAD IN THE EVENT OF A MAIN POWER NETWORK FAILURE.NO OVERLOAD IS PERMITTED.

These ratings are applicable for supply continuous electrical power (at variable load) in the event of a utility power failure. No overload is permitted on these ratings

#### STANDARD REFERENCE CONDITIONS

OUTPUT RATINGS ARE PRESENTED AT 30°C AIR INLET TEMPERATURE, BAROMETRIC PRESSURE 100 KPA, RELATIVE HUMIDITY 30%. THIS GENERATING SET IS DESIGNED TO OPERATE AT HIGH AMBIENT TEMPERATURES (UP TO 55°C), HUMIDITY (UP TO 99%) AND HIGHER ALTITUDES. DE-RATION MAY APPLY, PLEASE CONSULT YOUR DEALER FOR SPECIFIC SITE RATINGS AND SMOOTH OPERATION.

#### AVAILABLE OPTIONS & ACCESSORIES

WE OFFER A RANGE OF OPTIONAL FEATURES AND ACCESSORIES TO TAILOR OUR GENERATING SETS TO MEET YOUR POWER NEEDS.

THEOR SOR GENERALING SETS TO THEET TOOK TOWER INCESS.		
SOUND / WEATHER PROOF CANOPY	ATS / AMF PANELS	
SYNCHRONIZING PANELS	WATER FUEL SEPARATOR	
ADDITIONAL PROTECTION ALARMS AND SHUTDOWNS		
WATER JACKET HEATER	CABLING AND DUCTING	
REMOTE MONITORING SYSTEM	EARTHING SYSTEM	

THE RECOGNIZE BRAND OF



# 10. GENERATOR CONTROL PANEL MAKE DEEP SEA MODEL DSE-4520

THE MAIN CONTROL PANEL CABINET PROVIDES AN AUTOMATIC CONTROL FOR THE STARTING OF THE GENERATOR SET WHEN A MAINS FAILURE OCCURS. THE DSE-4520 IS AN AUTO START CONTROL MODULE FOR SINGLE GENSET APPLICATIONS. IT INCLUDES A BACKLIT LCD DISPLAY WHICH CLEARLY SHOWS THE STATUS OF THE ENGINE ALL THE TIMES, THIS MODULE CAN EITHER BE PROGRAMMED USING THE FRONT PANEL OR BY USING THE DSE CONFIGURATION SUITE PC SOFTWARE. THE CABINET INCLUDES.

- CIRCUIT BREAKER(S)
- Bus Bar
- MEASURING INSTRUMENTS
  - VOLTMETER
  - **AMPERE METER**
  - FREQUENCY METER
  - TIME (HOURS) REORDER
  - KILOWATT METER
- ALARMS
  - FAILURE TO START
  - Low Lubricating oil Pressure
  - UNDER/OVER VOLTAGE
  - OVER FREQUENCY
  - High coolant temperature switch
  - OVER CRANK
  - GENERATOR OVER LOAD
- GAUGES
  - OIL PRESSURE GAUGE
  - WATER TEMPERATURE GAUGE
  - RPM METER
  - CHARGING AMMETER
  - EMERGENCY STOP PUSH BUTTON
- SELECTORS
  - To select the generator's operating mode "off-automatic -manual and test"
  - To switch the generator to test position: "on-off"
- Pushbuttons
  - EMERGENCY SHUTDOWN RED BUTTON
- SAFETIES
  - FAILURE TO START
  - Low Lubricating oil pressure
  - UNDER/OVER VOLTAGE
  - OVER FREQUENCY
  - HIGH COOLANT TEMPERATURE SWITCH
  - OVER CRANK
  - GENERATOR OVER LOAD
  - FAIL TO START / OVER CRANK

#### 11. FACTORY TESTS

THE GENERATING SET IS LOAD TESTED BEFORE DISPATCH IN OUR FACTORY. ALL PROTECTIVE DEVICES ARE SIMULATED. THE GENERATOR AND ITS SYSTEM ARE CHECKED BEFORE DISPATCH.

#### 12. DOCUMENTATION

ONE SET OF COMPLETE SPARE PARTS LIST, ENGINE & ALTERNATOR MAINTENANCE MANUAL.

ONE SET OF ENGINE OPERATION MANUAL AND PART CATALOGUE.